



BIOSECURITY TECHNOLOGY LLC

FIGURE 1







BIO-SAFE SMALL GAS UNIT INSTALLATION

- 1. MOUNT UNIT TO A FLAT SURFACE
- 2. PLUG POWER CORD FROM BIO-SAFE GAS UNIT INTO DEDICATED 120V POWER SUPPLY

FUNCTIONAL INSTRUCTIONS

1. SET SELECTOR SWITCH TO THE DESIRED MODE

OFF - UNIT WILL BE POWERED OFF

TIMED - UNIT WILL REPEATEDLY CYCLE ON AND OFF ACCORDING TO TIMER SETTINGS. DEFAULT SETTINGS ARE 50 MINS ON AND 10 MINS OFF. NOTE: TIMER CAN BE REPROGRAMMED, SEE QR CODE FOR AN INSTRUCTIONAL VIDEO.


ON - UNIT WILL CONTINUALLY RUN


TROUBLESHOOTING


NOTE: UNIT SHOULD BE CHECKED BY A LICENSED ELECTRICIAN

- 1. ISOLATE POWER FROM UNIT BY UNPLUGGING FROM 120V SOURCE
- 2. USING A MULTI-METER ON OHMS SETTING, TOUCH PROBES TO TERMINALS AS INDICATED IN FIGURE 2
- 3. IF MULTI-METER READS "OL", THE FUSE MUST BE REPLACED (P/N: MDL-3-R)
- 4. IF FUSE IS FOUND TO BE OPEN AND REPLACEMENT DOES NOT RETURN UNIT TO NORMAL OPERATION, PLEASE CONSULT THE FACTORY









RIGHT VIEW

